

MAY 2013

From: Dan Van Buekenhout
To: Ron Christie
Subject: Re: Connaught School Inspection
Date: Friday, May 10, 2013 4:36:29 PM
Attachments: image001.jpg

No. That's what we were just talking about.
Dan Van Buekenhout

From: Ron Christie
Sent: Friday, May 10, 2013 04:35 PM
To: Dan Van Buekenhout (dan.vanbuekenhout@rbe.sk.ca)
Subject: FW: Connaught School Inspection

Has PCL banded the top of the school to prevent further deterioration of the bricks?

From: Brad Taylor [mailto:btaylor@jckenyon.com]
Sent: Friday, May 10, 2013 10:25 AM
To: Ron Christie
Subject: Connaught School Inspection

Hi Ron,

I have attached our most recent report from Connaught.

We recommended that the north side of the east stairs be blocked off. It appeared that they have moved more and some of the treads may be unstable.

Let me know if you have any questions.

Brad Taylor

Structural Engineer-In-Training



J C KENYON ENGINEERING INC.
STRUCTURAL ENGINEERING CONSULTANTS

2424 COLLEGE AVENUE
REGINA, SASKATCHEWAN S4P 1C8

Meeting of Administrative Council Executive (ACE)

Monday, May 13, 2013

9:00 a.m. to 10:30 a.m.

Director's Office

DECISIONS

FILE COPY

1. Board Meeting Items

May 21

- Student Health Initiatives Presentation (J. Redekopp-McKeown)
- Graduation Program Update (D. Boldt)?
- 2013-14 Budget Development
- SAMA Update
- Board and Director Evaluations

June 18

- Approve Positive Path Forward
- Approve Continuous Improvement Plan
- Review Annual Board Work Plan
- Approve 2013-14 Budget for Submission to Ministry of Education
- Public Education Advocacy Committee
- Audit and Policy Review Committee
- Strategic Planning Committee

September 3

- School Opening Update
- 2013-14 Budget Final Estimates (approve)
- Annual Board Work Plan 2013-14 (approve)

September 24

- SSBA: Submission of Bylaw Amendments and Resolutions for 2013 AGM
- 2012-13 School Community Councils Report

2. Pending Items – For Board Agenda

Pending Items – Return to ACE

- Admin Procedure-Anaphylaxis Management Program (Sept 6, 2011 ACE)
- Admin Procedure-Tributes and Expressions of Sympathy (Jan 30/12 ACE)
- Language Offerings and Space Requirements Review (April 16, 2012 ACE)
- Preschool User Groups and Space Requirements Report (April 16, 2012 ACE)
- Admin Procedure re risk management for school/group accounts (April 23, 2012 ACE)

3. Board Items

a) Review of Upcoming Board Agenda Items <u>As discussed.</u>	J. MacRae
---	-----------

4. Director's Items

a) Request for Accessibility Accommodation at Sheldon-Williams Collegiate (Attached)	J. MacRae <u>Action: Julie will reply that we are looking at design of the school to determine what accommodations can be made.</u> <u>Action: Debra to discuss with Facilities.</u>
--	--

5. School Services Items

a) Connaught School – Centennial Plaque (Attached) <u>Installation of plaque approved.</u>	M. Walter <u>Action: To be placed on Board Pink Sheets.</u>
--	---

6. Student Achievement Items

a) Draft Continuous Improvement Plan 2013-14 (Attached) <u>Draft reviewed and edits made.</u>	G. Enion <u>Action: Draft to be forwarded to Strategic Planning Committee for the Wednesday, May 15, 213 meeting.</u>
b) Cell Phones for Elementary VPs (Attached) <u>From Wednesday, May 8 ACE meeting</u>	G. Enion <u>Action: Debra to discuss with Bruce Lipinski; and, Greg will review SA budget.</u>

7. Division Services Items

a)	D. Burnett
----	------------

8. Personnel Items

a)	
----	--

5a

From: Luc Lerminiaux
Sent: Thursday, May 09, 2013 8:17 AM
To: Greg Enion; Mike Walter
Subject: FW: Bronze Plaque

Hi Gentlemen. Can you take this to ACE for approval to be installed at Connaught in commemoration of their centennial year. I think they must be short the 6 million in fundraising so settled for this? Thx Luc

From: Chris Keyes
Sent: Wednesday, May 08, 2013 4:28 PM
To: Luc Lerminiaux
Subject: FW: Bronze Plaque

Hey Luc. Please have a look at this e-mail from the Centennial Committee. Not really sure what the process is for approving the installation of the pedestal and plaque but Terry Lazarou thought it probably had to go through you to ACE and perhaps beyond to the board.

Cheers, Chris

→ **From:** Connaught Centennial [<mailto:connaught100@gmail.com>]
Sent: May-08-13 2:10 PM
To: Carla Beck; Chris Keyes; Crystal Proulx; Elaine Barrow; Gerri Ann Siwek; Jacqueline Roy; Janine Windolph; Kathleen Harel; Leslie Charlton; Molly Moss; Patricia Elliott; Rene Dumont; Robin Tresos; Sheila Jozsa; Suzanne Arndt; Chris Selinger & Sheri Adams-Selinger
Subject: Bronze Plaque

Hi everyone,

Here is the final rendering of the bronze plaque, which will be ready in 4 to 6 weeks, a fitting end to the centennial year, and the final obligation of our federal funding.

It comes with pedestal, as our grant application stated it would be placed near the sidewalk for maximum public view. It can be moved or remain however future circumstances may dictate, but in any case we will have a record in bronze of our school history, with a picture as it looked in 1912.

Rene, would you be the one to contact the board office re. installation? Or would that be Chris, or me as committee chair? I will get information from the company about what is required.

Thanks go to Jonathan Yardley and Bill Brennan for assisting with the text, to Briane Noyes for translation, and to Joan Main for design.

Also, there may be a request coming for funding for lighting for a school performance, am awaiting further details.

- Trish

1/4"-20 x 4" Stainless
Steel Threaded Pins
0.625"



OFFICE USE ONLY

PROOFING	INITIALS	DATE
DESIGN		
SALES		

PROJECT INFORMATION

PROJECT	
SALES	k1
ARTIST	b1
REVISION	02
DATE	Apr. 23, 2013
STATUS	review
FILE	005997
SCALE	see to left for scale (for output on 11x17)

☐ OK - Proceed Manufacturing

☐ Corrections Required

PLEASE CHECK CAREFULLY. ALL ERRORS
OMISSIONS NOT MARKED AT THIS STAGE
THE RESPONSIBILITY OF THE CUSTOMER


Customer Signature: _____

Date: _____

Page 01 of 01

École Connaught, fondée en 1912

En juin 1972, la commission scolaire de Regina a ordonné la fermeture d'une école pour l'ouverture de la ville alors en plein développement. Malgré une grande dévastation qui a détruit la ville la même année, l'Université de Regina a continué à fonctionner. L'école a été fermée à la fin de l'année scolaire 1972-1973. L'école a été fermée à la fin de l'année scolaire 1972-1973. L'école a été fermée à la fin de l'année scolaire 1972-1973.



Ferazou, un élégant portrait à l'encre et de larges contours postmodernes. En 1976, l'école Connaught a mis en place un programme d'immersion française et, en 1980, la collectivité locale a contribué à la démantèlement de l'école communautaire, rendant l'école d'immersion française une école communautaire. Cette école a été créée d'un programme pilote de l'école Connaught à deux classes, la première, la seule et unique école à deux classes d'immersion française au Canada pendant plusieurs années. Elle possédait un héritage créatif impressionnant composé de plusieurs musiciens, artistes, interprètes et écrivains liés à l'école et au quartier du Cathedral Village qui l'entoure. En 2012, la Fondation Héritage Canada a reconnu le rôle de cette école dans le développement national.

Connaught School, established 1912

In June 1912, Regina's public school board ordered construction of a school for the city's growing west end. Despite a devastating tornado, and a new school for the city by the same name, Parsons Construction was the chosen firm. It began its work on the city's new school in 1912, and completed it in 1913. The school was named in honour of H.R. James Arthur, Duke of Connaught and Canada's Governor General from 1911 to 1916, in honour of the Prince's visit to Regina in October 1912. Architect J.H. Munlin, who resided at nearby 2256 Rae Street, described the building as follows:

is design as "nearly simple." Buildings, Connaught became a template for future Canadian public architecture, with an emphasis on practicality, economy and beauty. Its 17 classrooms were square-shaped to allow creative seating arrangements beyond the traditional oblong "teacher-in-the-front" configuration. Other features included terrazzo floors, an elegant entrance and multi-purpose hallways lit by tall windows. In 1976

Connaught introduced a French immersion program in 1980. The surrounding community helped pilot a community schools program. The surrounding community school is the first, and, for many years, only making Ecole Connaught Community School in Canada. The school also making track (French-English) community school in Canada. The school also enjoys an impressive creative legacy, with many musicians, artists, performers and writers connected to the school and its surrounding Cathedral Village neighbourhood. In 2012, Heritage Canada recognized Connaught's national significance.

Érôle Connaught Centennial Committee / le comité centenaire de l'Érôle Connaught
Canadian Heritage / Patrimoine canadien
June 2013

*Image of building contains fine lines and may not manufacture exactly as shown
some loss in detail will occur*

- raised & brushed finish
- recessed, textured & inflated

Plaque Elevation
SCALE: 1:4

Page 01 of 01

From: Brad Taylor
To: Ron Christie
Subject: RE: Connaught School Inspection
Date: Thursday, May 16, 2013 9:10:26 AM
Attachments: image001.jpg

Hello Ron,

I did notice the odd little crack here and there, but I don't think repointing is necessary at this time.

If you have some money in the budget for this school why don't we fix that one wall in the north west classroom on the main floor. I think it will only get worse aesthetically because the kids will pick away and damage the cracked drywall. We could demo the existing wall and fill it in with steel studs and drywall.

That is what I would focus on right now.

Brad

Brad

From: Ron Christie [mailto:ron.christie@rbe.sk.ca]
Sent: May 10, 2013 4:35 PM
To: Brad Taylor
Subject: RE: Connaught School Inspection

Thanks Brad
Anything else we need to do. Repointing?

From: Brad Taylor [mailto:btaylor@jkenyon.com]
Sent: Friday, May 10, 2013 10:25 AM
To: Ron Christie
Subject: Connaught School Inspection

Hi Ron,

I have attached our most recent report from Connaught.

We recommended that the north side of the east stairs be blocked off. It appeared that they have moved more and some of the treads may be unstable.

Let me know if you have any questions.

Brad Taylor
Structural Engineer-In-Training



J C KENYON ENGINEERING INC.
STRUCTURAL ENGINEERING CONSULTANTS

2424 COLLEGE AVENUE
REGINA, SASKATCHEWAN S4P 1C8